



FOT 1230

EXTINGUISHING SYSTEM

Company Name: _____

Hazard Area: _____

Installation Address: _____

Site Contact Name: _____

Site Extension No.: _____

FOT Contact No.: _____

FOT Fire Control

Unit 3 Merchant,
Evegate Business Park,
Smeeth Ashford,
Kent TN 24 9RS,
UK



SECTION

1	Responsible person and record of personnel training.....	3
2	Inventory of extinguishing equipment.....	4
3	General Guidance.....	5
4	Inspection and Maintenance.....	9
5	Cosh Data Sheet.....	12
6	Events Log.....	16
7	Weekly Routine Inspections.....	17
8	Record of extinguishing maintenance.....	20
9	Alteration to system.....	23



RESPONSIBLE PERSON & TRAINING – SECTION 1

Responsibilities person and staff extinguishing system training Responsible person

Deputy

DATE	NAME	POSITION	SIGNATURE

The extinguishing system to which this guide refers has been designed and tested in accordance with BS ISO 14520.

The user is required to carry out a program of inspection. And to arrange a service and maintenance schedule.

This manual is not to be considered a detailed installation, operation and maintenance or design manual. If a copy of the installation, operation and maintenance manual is required, it may be obtained from FOT Fire Control.

This system is made up of units tested within the limitations contained in the detailed installation manual. The system designer must be consulted whenever changes are planned for the system or area of protection. An authorized installer or system designer must be consulted after the system has discharged.



INVENTORY OF EQUIPMENT – SECTION 2

Protected Area.....

Date of Commissioning

Quantity of FOT-1230

Number of Containers.....

Agent per Containers.....

Weight of Containers.....

Number of Nozzles.....

Number of Pressure Switches

Number of Release Solenoids.....

Number of Manual Release Units.....

Number of Door Signs.....



GENERAL GUIDANCE – SECTION 3

General Handling

Training should be given to all personnel handling containers. All regulations and local requirements regarding their handling and storage should be observed. Ensure that you comply with all your statutory obligation in regard to maintenance and testing. Do not remove or deface labels provided by FOT for Identification of gas and operation of the container. Establish and implement plans to cover any emergency situations that might arise. When in doubt as to correct handling procedures, consult FOT Fire Control.

Enclosure

For the extinguishing system to function effectively, the integrity of the protected area must be maintained. Therefore, it is important to ensure that there are no gaps around windows and doors, and that all entries for cables, pipes, etc. are sealed. The operation of any automatic closing devices, doors etc. should be routinely verified. All services within the area likely to impair the efficiency of the extinguishing system must be shut down prior to discharge.

At least every twelve months, the enclosure should be thoroughly inspected to determine if penetrations or other changes have occurred that could adversely affect extinguishing leakage or cause change of volume, or both.

Storage

Containers in storage or use should be protected from direct sunlight and other severe climatic conditions. Containers should be stored in a well ventilated room. Containers should not be subjected to any direct source of heat and should be kept below 50°C.

- Containers should be stored in a well ventilated area away from source of heat.
- Containers should be protected against conditions likely to encourage corrosion
- Vertical storage is recommended and containers should be properly secured to prevent toppling or rolling.
- The storage area should be kept clear and access should be restricted to authorized persons only.
- Enter an enclosed area only after notifying a colleague nearby.
- The area should be clearly marked as a store and appropriate hazard warning signs displayed.



GENERAL GUIDANCE – SECTION 3

Precautions

- Wear stout gloves, shoes and suitable eye and face protection when transporting containers.
- Use a cylinder trolley or other applicable system for transporting containers even short distances.
- Before connecting the container, check the system for suitability, pressure rating and materials.
- A container should not be subjected to temperature above 50°C.
- Do not use containers for any purpose other to contain the gas originally supplied.
- Keep all valve outlets clean and free from contaminants, particularly oil and water.
- Never attempt to affect repairs or modifications to valves or safety relief devices.
- Damage to valves and safety devices should be reported to FOT immediately.
- Be aware that all the containers on a manifold must be the same size, fill and pressure.
- Never use direct flame or electrical heating devices to raise the pressure of a container.

Health and Safety

A properly installed and maintained extinguishing system should not present any significant health and safety problems providing basic precautions are taken and staff have an understanding of the system operation.

Emergency Action

In event of system leaks

If containers are in enclosed area, evacuate the area and arrange for it to be ventilated. Do not re-enter the area until the level of FOT-1230 have dropped. Contact FOT regarding repair of the system.

First Aid – Direct Contact with Vaporizing Liquid

Skin – Flush with soap and water, if frostbite occurs seek medical attention.

Eye – Flush with clear water, seek medical attention.



GENERAL GUIDANCE – SECTION 3

Action in the event of fire protected area

- Ensure no personnel are left in the room.
- Contact the emergency services.
- Do not re-enter the enclosure until told and you may do so by emergency service.
- Ensure the containers are refilled immediately by a competent supplier. This work can be carried out by FOT.

Action in the event of the in the container store

In general, do not take risk. Vacate the area, call the emergency services. If unable to extinguish fire, cool containers with water hosed from a safe distance. Inform emergency services of the nature of the product and, in the case of containers, the possibility of burst disc rupture. The container valve is fitted with a bursting disc which will rupture and allow the contents to completely discharge if heat causes the pressure to exceed the maximum permissible service level. Notify FOT Fire Control of any container involved in a fire.

Environmental / Toxicology

	FOT-1230
Environmental	
Ozone Depletion	0
Atmospheric Lifetime (yrs)	0.019
Toxicology	
Acute Exposure LC ₅₀ (ppm)	>100,000
Cardiac Sensitization	Not a Sensitizer (NOAEL = 100,000 ppm)
No observed adverse effect level (NOAEL)	10%
Lowest observed adverse effect level (LOAEL)	LD ₅₀ > 2000 mg/kg



GENERAL GUIDANCE – SECTION 3

Agent Physical Properties

Properties	FOT-1230 fluid
Chemical Formula	CF ₃ CF ₂ C(O)CF(CF ₃) ₂
Molecular Weight	316.04
Boiling Point @ 1 atm	49.2°C (120.6°F)
Freezing Point	-108.0°C (-162.4°F)
Critical Temperature	168.7°C (335.6°F)
Critical Pressure	18.65 bar (270.44 psia)
Critical Volume	494.5 cc/mole (0.0251 ft ³ /lbm)
Critical Density	639.1 kg/m ³ (39.91 lbm/ft ³)
Density, Sat. Liquid	1.60 g/ml (99.9 lbm/ft ³)
Density, Gas @ 1 atm	0.0136 g/ml (0.851 lbm/ft ³)
Specific Volume, Gas @ 1 atm	0.0733 m ³ /kg (1.175 ft ³ /lb)
Specific Heat, Liquid	1.103 kJ/kg°C (0.2634 BTU/lb°F)
Specific Heat, Vapor @ 1 atm	0.891 kJ/kg°C (0.2127 BTU/lb°F)
Heat of Vaporization @ boiling point	88.0 kJ/kg (37.9 BTU/lb)
Liquid Viscosity @ 0°C/25°C	0.56/0.39 centistokes
Vapor Pressure	0.404 bar (5.85 psig)
Relative Dielectric Strength, 1 atm (N ₂ =1.0)	2.3

Toxicity testing results

Properties	FOT-1230 fluid
4-hour Acute Inhalation	Practically Non-Toxic (LC ₅₀ > 100,000 ppm)
Cardiac Sensitization	Not a Sensitizer (NOAEL = 100,000 ppm)
Acute Dermal Toxicity	Low Toxicity (LD ₅₀ > 2000 mg/kg)
Ames Assay	Negative
Primary Skin Irritation	Non-Irritating
Primary Eye Irritation	Minimally Irritating
Acute Oral Toxicity	Low Toxicity (LD ₅₀ > 2000 mg/kg)
Skin Sensitization	Not a Skin Sensitizer
28-Day Inhalation Study	NOAEL of this study: 4,000 ppm
Chromosomal Aberration	Negative



INSPECTION AND MAINTENANCE – SECTION 4

Introduction

This section provides user inspection and maintenance guidance for FOT 1230 engineered systems. A log book is provided to record all inspections, maintenance, measurements and actions taken. It is a legal requirement (the 1989 Pressure Systems and Transportable Gas Container Regulations) that a written plan is drawn up for servicing the installed system.

The plan should state “when pressurized vessels be inspected, ensure inspection of related pipe fittings and list all of protective devices”. It is recommended that a room integrity test is performed once a year by a qualified service engineer and this work can be carried out by FOT.

User’s Programme of Inspection

Weekly

1. Inspect the hazard area against the original layout that there have been no changes that might affect the proper performance of the fire protection system. Changes might include:
 - Contents of area
 - Use of Area
 - Air handling equipment in area
 - Openings in area
 - Floor/Ceiling voids
 - Partitioning
2. Check storage container pressure gauge(s) and ambient temperature, compare the pressure(s) to the temperature correction chart to determine temperature corrected pressure. If the container has been fitted with a Watchman Weigh base, check the fault indication light. Any container that shows a loss in net content of more than 10% shall be refilled or replaced. All measurements and actions shall be recorded in the log book.
3. Make a visual inspection of the system components, distribution piping and nozzles. Check the immediate vicinity of all equipment to ensure that no accidental damage or tempering has occurred.
4. Inspect the hazard area, access routes, container storage area, floor voids and areas above suspended ceilings to ensure housekeeping is good and that no refuse has accumulated. Ensure that access to the system container assemblies and local remote controls are unobstructed.



INSPECTION AND MAINTENANCE – SECTION 4

User's Programme of Inspection Cont.

Monthly

1. Inspect the system and protected spaces to ensure that warning signs, safety precautions and operating instructions are posted and clearly visible.
2. Check that all persons who are expected to inspect, test, maintain or operate the fire extinguishing system are kept adequately trained in the function they are expected to perform.

Personnel working in an enclosure protected by FOT-1230 shall receive training in the operation and use of the system and safety issues.

Contracted Service & Maintenance

3 Monthly

1. Test and service all actually mechanisms
2. Test and service all electrical detection and alarm system as recommended is BS 5411:2001

6 Monthly

1. Externally inspect for signs of damage or unauthorized modifications.
2. Verification of the content of FOT-1230 in the container may be achieved through either liquid level detection or container weighing.

Liquid Level Detection

FOT use ultrasonic or gamma radiation liquid level detection equipment. This provides a rapid measurement of the contents without disturbing the container from storage racks. If required, this special liquid level detection equipment may be purchased from FOT.

Container Weighing

Where a client does not wish to use a FOT maintenance contract or the specialized liquid level detection equipment, then containers must be weighed to establish the FOT-1230 content.



INSPECTION AND MAINTENANCE – SECTION 4

Contracted Service and Maintenance

6 Monthly count.

- 3) A check of all manual and pneumatic actuators for free movement of the piston. Replace whole unit where appropriate.
- 4) Check all control valves for correct manual function and automatic valves additionally, for correct automatic function.
- 5) An external check of the pipework to determine its condition. Pressure test and replace or repair as necessary, pipework showing corrosion or mechanical damage.
- 6) An inspection of nozzle for dust debris, clean out where necessary.

Yearly

- 1) All system hoses should be examined for damage. If visual examination shows any deficiency, the hose shall be replaced.
- 2) Every 12 months an integrity test should be carried out on the enclosure to determine if the leakage has changed sufficiently from that measured during installation.

Contracted Service and Maintenance

Container Hydrostatic Pressure Testing

Hydrostatic pressure testing of any container is required every ten years in accordance with BS 5430 part 2 section 4 1990.

Container in fixed system may remain for twenty years providing they have not been discharged during this period and the containers have been subject to a full external examination every 6 months from the date of entry into services. However, it is advisable to remove container from services once in ten years and return then to an approved testing /recharging agent for inspection.



COSH DATA SHEET – SECTION 5

Identification of substance and Company

Chemical Name:	dodecafluoro-2-methylpentan-3-one
General Use:	Fire Extinguishing
Chemical Family:	fluoroketone
Emergency Telephone:	+44 333 2244 360
Supplier:	FOT Fire Control Unit 3 Merchant, Evegate Business Park, Smeeth Ashford, Kent TN 24 9RS, UK

Composition/Information on Ingredients

Component	Weight%	EEC Number
dodecafluoro-2-methylpentan-3-one	100%	2070793

Hazard Identification

This material has no hazardous physio-chemical properties or health effects, based upon the criteria laid down by chemical (Hazard information and packaging regulation 1990).

First Aid Measures

Inhalation:	Remove person to fresh air and get a medical attention
Eye Contact:	Flush with water for 15 minutes. Get a medical attention
Skin Contact:	Wash with soap and water. If frost bite occurs, get a medical attention
Ingestion:	Not Applicable

Fire Fighting Measures

General hazards:	This material is designed as an extinguisher and will not sustain combustion
Firefighting instruction:	Not Applicable
Firefighting equipment:	Not Applicable
Unusual fire and explosion hazards:	This material is stored in a pressurized container



COSH DATA SHEET – SECTION 5

Accidental Release Measures

Air Release: Evacuate area. Ventilate and allow to disperse.

Land Spill: Not Applicable

Water Spill: Not Applicable

Handling and Storage

Storage Temperature: Ambient. Storage: 25 bar (at 20°C)

Precautions: Store in a cool well ventilated area.

Exposure Control/Personal Protection

Engineering Measures: Ventilation System.

Occupational Exposure: LOAEL: LD₅₀ > 2000 mg/kg)

NOAEL: 10.0%

The US EPA allows unrestricted use up to 10% for firefighting, and up to 10.5% where degree can occur within 1 minute.

Personal Protective Clothing

Respiratory: Self-contained breathing apparatus if concentration exceeds or is likely to exceed 10%

Hand/Skin: Lined Neoprene gloves when handling liquid

Eye Protection: Anti-splash goggles when handling liquid.

Hygiene Practices: Wash hands with soap and water after handling and before eating. Launder contaminated clothing before re-use

Physical and Chemical Properties

Physical State: Liquefied Compressed gas

Color: Colorless

Odor: None

Vapor Pressure: 0.404 bar (5.85 psig)

Specific gravity: 1.46

Solubility: Not available



COSH DATA SHEET – SECTION 5

pH: Not available
Boiling Point: 49.2°C (120.6°F)
Viscosity: 0.56/0.39 centistokes
Vapor Density: Not available
Flash Point: None
Flammable Limits: None
Auto ignition Temp: None

Other

Stability and Reactivity

Stability: Stable
Hazardous Reactions: None Known
Incompatibility with: None Known

Toxicological Information

Inhalation Lc50 (rat):>100,000ppm

Ecological Information

Details for Ecology: US EPA has confirmed the Ozone Depleting Potential (ODP) for FOT as Zero.
The Atmospheric Lifetime is 0.019 year.

Disposal Considerations

This material should be incinerated in a high temperature chemical waste incinerator fitted with acid gas scrubbing systems. All disposal should be in accordance with local, state and European law.

Transportation Information

Hazard Classification: Non-Flammable Compressed gas
Substance Identification Number: 3298
Packing Group: Not Applicable
IMDG Code Page Number: 21441
Proper Shipping Name: dodecafluoro-2-methylpentan-3-one
RID/ADR: Class 2



COSH DATA SHEET – SECTION 5

Regulatory Information

Labelling: This material is not classified as hazardous for supply under the Chemical (Hazardous Information and Packaging) Regulation 1993.

“R” Phases: None

“S” Phases: 15: Keep away from heat
21: When using, do not smoke
38: In case of insufficient ventilation, wear suitable respiratory equipment.

This material is covered by the “Control of Substances Hazardous to Health Regulations 1988”

The data contained herein is based on information currently available to us and believed to be factual and the opinions expressed to be those of qualified experts: however, this data is not to be taken as a warranty or representation for which Great Lakes Chemical (Europe) Ltd assumes legal responsibility.



WEEKLY INSPECTION – SECTION 7

Dates	Comments	Actions	Signature



RECORD OF MAINTENANCE – SECTION 8

Date	Comments	Parts Used	Next Visit Due	Initials



RECORD OF MAINTENANCE – SECTION 8

Date	Comments	Parts Used	Next Due	Visit	Initials



ALTERATIONS TO SYSTEM – SECTION 9

Date	Description	Contractor	Recommissioned	Initials

